

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202810
Address: 3008 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Wednesday, February 03, 2021

Corrective Action Required:

1	Misc	-Properly fireblock vertical to horizontal, GR chase -Exterior Braced wall Method CS-PF (exterior fastening per plan), GR exterior wall -Rim board header ends or splices required to span minimum 6 inches past outer full height stud of opening, Above basement windows -Maintain clearance to combustibles per listing of flex flue connector at furnace -Deck- post/beam connection per code
---	------	--

OK TO INSULATE

Comments: