

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203528  
Address: 2346 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	John Morris	Failed	Wednesday, February 03, 2021

Partial Correction:

1	Misc	-Erosion control requires continuous maintenance. Establish at curb within 48 hours or stop work order will be issued -no further inspections until issues are resolved
---	------	--

**Comments:**