




February 3, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Jack studs supporting LVL headers in basement Lot # 17 Hawthorne Ridge – 3008 SW Arboridge Dr. Lee's Summit, MO 64082 – Permit # PRRES20202810

This letter addresses the (2) #2 2x6 jack studs supporting the LVL headers in the basement.

- Basement headers for (2) 5050 slider windows underneath great room shall be (2) 1-3/4" x 9-1/4" LVL Versa-Lam 2.0E 3100 Fb spanning approximately 5' with (2) #2 Douglas Fir Larch 2x6 jack studs as shown below.



Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

