

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204749
Address: 1500 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, February 04, 2021

Corrective Action Required:

1	Misc	-SET INTERIOR DRAIN TILE - IF SETTING DRAIN TILE HORIZONTAL ACROSS FLOOR MUST GO DIAGONAL FROM SUMP PIT AND REACH OPPOSITE FOUNDATION WALL
---	------	--

Comments: