

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204028  
Address: 10 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Michael Harkins	Partial	Friday, February 05, 2021

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | - ROOM M43 -<br>- ROOMS M04,M05,M06,M07,M09,M10,M11,M12 -<br>- ROOMS M32,M33,M34,M35,M38,M39,M40-<br><br>- M36 FIRE CAULK CONDUIT AT BOTTOM PLATE - |
|---|------|---|

**Comments:**