

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204442
Address: 2009 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Michael Harkins	Failed	Monday, February 08, 2021

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged sections at curb and establish methods rear of lot within 48 hours -provide and maintain gravel filter -no further inspections until issues are resolved
---	------	---

Comments: