

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202110
Address: 2931 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, February 08, 2021

Corrective Action Required:

1	Misc	-Complete final grade per approved plot plan and sod -Splash blocks at all sump pump and down spout locations, minimum 36" distance from foundation -Seal all penetrations in siding, seal along top of AC disconnect and meter can -Remove all construction debris from lot -Install range hood, exposed NM -No setback allowed with combustible material at living room floor receptacle -Flashing at front window trim
---	------	---

Comments: