

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202013
Address: 3121 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, February 09, 2021

Corrective Action Required:

1	Misc	-Seal all top and bottom plate penetrations -unused bottom plate bore laundry, master closet bottom for NM, E wall -Install back door at deck **OK TO INSULATE**
---	------	--

Comments: