

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20203927	Date:	February 10, 2021
Project Title:	HY-VEE #2 REMODEL	Applicant:	
Location:			
310 SW WARD RD, LEES SUMMIT, MO 64081		CONTINENTAL FIRE SPRINKLER COMPANY	
Type of Work:		4518 S 133RD ST	
Occupancy Group: M		OMAHA, NE 68137	
Description:	INTERIOR REMODEL OF EXISTING	Primary: (402) 330-5170	
GROCERY STORE			
Construction Type:	Type IIIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Sprinkler Plan Review**

**Reviewed By: Michael Weissenbach**

**Released for Construction**

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

(Informational Purposes)

Call (816)969-1300 to schedule a hydrostatic test.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**