

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202961  
Address: 2366 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                | Inspector:  | Outcome: | Date:                        |
|--|-------------|----------|------------------------------|
| <b>Gas Piping Inspection - Residential</b> | John Morris | Failed   | Wednesday, February 10, 2021 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | Pressure test gas piping minimum 10psi for 15 minutes |
|---|------|---|

**Comments:**