

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20192766  
Address: 1104 NE GOSHEN CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Khanh Nguyen	Failed	Wednesday, February 10, 2021

Corrective Action Required:

1	Misc	-Not-ready fee accessed on Feb-07 has not been paid. No occupancy shall be issued until the fee, the piers approval, and all interior deficiencies are corrected  -Piers not approved by the city. Have engineer submit letter to the city approving the piers  -Install downspout and sump pump extensions -Install the sewer tracer wire and port  -Lag the deck ledger board through the spacers; install and support outer deck joists per code
---	------	--

Comments: