

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202000  
Address: 4404 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Wednesday, February 10, 2021

Corrective Action Required:

1 Misc

-basement stairs, (2) 2x10 at stringer with bearing on 3" SCH 40 steel column on pier pad "A" per plans pier schedule

Studs that were installed do not touch the 2-2x10's.  
install full length studs or install approved shims.

**Comments:**