

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20204028	Date:	February 10, 2021
Project Title:	LEES SUMMIT POLICE DEPARTMENT - INTERIOR ALTERATIONS AND ADDING FLOOR SPACE TO UPPER LEVEL	Applicant:	ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015
Location:	10 NE TUDOR RD, LEES SUMMIT, MO 64086		
Type of Work:		Primary:	(816) 224-3400
Occupancy Group:	I-3		
Description:	ALTERATIONS TO EXISTING POLICE STATION THAT INCLUDES ADDED SQUARE FOOTAGE TO UPPER LEVEL BY ADDING FLOOR SPACE OVER OPEN AREA		
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule a hydrostatic test.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.