

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20182613
Address: 905 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, February 11, 2021

Corrective Action Required:

1	Miscellaneous Correction	3RD FLOOR 307 secure guardrail on deck 304 missing railing. 2ND FLOOR 204 missing railing 1ST FLOOR 113 electrical wire at microwave/hood G10- garage door switch missing. G11-garage door switch missing G6- covered sprinkler heads Riser room -seal penetration roof top-remove trash Secure stairwell windows
---	--------------------------	---

Corrective Action Required:
2 Miscellaneous

Correction

3RD FLOOR

307 secure guardrail on deck
304 missing railing.

2ND FLOOR

204 missing railing

1ST FLOOR

113 electrical wire at microwave/hood
G10- garage door switch missing.
G11-garage door switch missing
G6- covered sprinkler heads

Riser room -seal penetration
roof top-remove trash
Secure stairwell windows

Comments: