

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202000
Address: 4404 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Thursday, February 11, 2021

Corrective Action Required:

1	Misc	-basement stairs, (2) 2x10 at stringer with bearing on 3" SCH 40 steel column on pier pad "A" per plans pier schedule
---	------	---

Studs that were installed do not touch the 2-2x10's.
install full length studs or install approved shims.

Comments: