

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20202107  
Address: 4408 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:         | Outcome:  | Date:                       |
|---|--------------------|-----------|-----------------------------|
| <b>All Rough Inspection - Residential</b> | Patrick Schonfeldt | Not Ready | Thursday, February 11, 2021 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | -Floor joists penetration for pex less than 2" apart, 1st floor living room near windows - replace or submit engineered solution<br>-Penetrations for NM in floor joists less than 2" from end of joist -Several locations throughout basement - replace or submit engineered solution<br><br>-DWV cleanout covered at bottom basement stair - plumbing contractor on site working on issue at time of inspection |
|---|------|---|

**\*\*OK TO INSULATE\*\***

ENG letter does not address multiple locations.  
Please address all location , some joist were added in the basement.

**Comments:**