

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201715
Address: 3129 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, February 11, 2021

Corrective Action Required:

1	Misc	-Cannot verify garage portal hold down straps embedded into concrete, required per R602.10.6.2, see detail S2.0
---	------	-----------------------------------------------------------------------------------------------------------------

OK TO INSULATE AND ROCK

Comments: