



PLAN REVIEW CONDITIONS

February 12, 2021

Van Deurzen and Associates
11011 King Street, Suite 130
overland park, KS 66210

Permit No: PRCOM20210580
Project Title: WASH HOUSE LAUNDRY
Project Address: 711 SE M 291 HWY, LEES SUMMIT, MO 64063
Parcel Number: 61510018101000000
Location: POLK ADDITION LOTS 5A & 5B---LOT 5A (EX PT DAF: BEG SE COR LOT 5A TH S 26.05' TH N 110' TH E 26.05'
Type of Work: CHANGE OF TENANT
Occupancy Group: BUSINESS
Description: TENANT FINISH FOR FULL SERVICE LAUNDROMAT

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Joe Frogge

Pending

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building , each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

