CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200316

Address: 1704 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Morris Failed Friday, February 12,

Residential 2021

Corrective Action Required:

1 Misc -Submit as graded plot plan for approval

-sump piping to discharge minimum 36 inches from foundation

-Minimum 6 inch clearance from wood siding to grade below

-Grade must fall minimum 6 inches in the first 10 feet from foundation -Seal all exterior penetrations, top and sides of A/C disconnect and electric

meter enclosure

-All exterior receptacles required to be GFCI protected

-Garage/dwelling separation door required to be self closing and self

latching

-Provide return air path for Northwest basement bedroom

-Properly attach lighting fixture and secure lighting outlet box in under stair

storage area

Comments: