

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202250
Address: 1400 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Partial	Friday, February 12, 2021

Corrective Action Required:

1	Misc	-Install security blocking for all exterior doors; fill in gaps with solid wood at: at strike side 12" on each side of strike plate; fill in gap at each hinge -Over-filled electrical box at upper stair landing
---	------	--

****OK TO ROCK AFTER DONE WITH THE ABOVE AND SEND IN PICTURES TO KHANH.NGUYEN@CITYOFLS.NET**

Comments: