


**RESIDENTIAL ENGINEERING SERVICES, LLC.**  
 SHOP DRAWINGS/SUBMITTAL REVIEW


SUBMITTAL WAS REVIEWED FOR DESIGN CONFORMITY AND GENERAL CONFORMANCE TO CONTRACT DOCUMENTS ONLY. THE CONTRACTOR IS RESPONSIBLE FOR CONFIRMING AND CORRELATING DIMENSIONS AT JOBSITE FOR TOLERANCE, CLEARANCE, QUANTITIES, FABRICATION, COORDINATION OF HIS OR HER WORK WITH OTHER TRADES, AND FULL COMPLIANCE WITH CONTRACT DOCUMENTS.

STATUS:  
**APPROVED**  
 01.17.2021  
 REVIEWED BY:  
**BH**  
 ENGINEER, RESIDENTIAL ENGINEERING SERVICES, LLC



HANGER SCHEDULE	Quantity
LUS24	16
LUS26	0
HUS26	2
HHUS26-2	0
HGUS26-2	0
HGUS28-3	0
LTHJA26	1
TJC37	6
TJC57	0
HTS20	0

Triangle denotes the left end of the Truss as it appears on the Engineered Drawings provided.



Unless otherwise specified by Engineer Of Record, Wheeler Lumber, LLC recommends an uplift connection at each bearing point per the following:

# of Uplift	Connector
0 - 495:	(1) H2.5A
495 - 990:	(2) H2.5A
990 - 1245:	(1) HTS20

Installation per Simpson Strong-Tie guidelines.

For Reactions greater than 1245#, refer to EOR.

Wall Heights 9'-01"-02' U.N.O.

11-06-12
12-01-02

**RELEASE FOR CONSTRUCTION**  
 AS NOTED ON PLANS REVIEW  
 DEVELOPMENT SERVICES  
 LEE'S SUMMIT, MISSOURI  
 02/12/2021


Customer	Job Name	Job Site Address	City, State	Designer
SUMMIT HOMES	Lot 80 Woodside Ridge	317 NW Ambersham	Lee's Summit, MO	Chance 785-746-4240

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY. These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing for the trusses during construction. The building designer is responsible for general guidance regarding bearing wall/beam/wall and column to the responsibility of the building designer. For general guidance regarding bearing wall/beam/wall and column, see the Truss Plate Institute, 583 Doherty Drive, Madison, WI 53179.

THIS LAYOUT IS THE SOLE SOURCE FOR FABRICATION OF TRUSSES AND VOIDS ALL PREVIOUS ARCHITECTURAL OR OTHER TRUSS LAYOUTS, REVIEW AND APPROVAL OF THIS LAYOUT MUST BE RECEIVED BEFORE ANY TRUSSES WILL BE BUILT. VERIFY ALL CONDITIONS TO INSURE AGAINST CHANGES THAT WILL RESULT IN EXTRA CHARGES TO YOU.

Shop Drawing Approval  
 Approved By: \_\_\_\_\_ Date: \_\_\_\_\_

**Wheeler Lumber**  
 1959 Old Hwy 50 NE  
 Waverly, KS 66871



**Roof Truss Layout**  
 Scale: 3/16" = 1'