
TYPE OF REVISION (**Addendum #1**)

Project name PetSuites of America – Lee’s Summit, MO Date 02.12.2021 Job No 2020155.27

- A. The **Bidding Documents** for the above referenced project are hereby revised as noted in **Addendum 1**.
- B. This **Addendum** supersedes and takes precedence over information provided prior to the date of this **addendum**.
- C. **Bolded responses** are in response to plan review comments received 02.08.21.

CHANGES TO THE SCOPE OF WORK DRAWINGS:

- 1. **Sheet A0.0:**
 - a) Added revision information to the cover sheet.
- 2. **Sheet A0.4**
 - a) **Added note G in General Notes. "G.C. TO INSTALL KNOX BOX PER LOCAL JURISDICTIONAL REQUIREMENTS. CAN BE SURFACE OR FLUSH MOUNT. THE KEY BOX SHALL BE OF AN APPROVED TYPE AND SHALL CONTAIN KEYS TO GAIN NECESSARY ACCESS AS REQUIRED BY THE FIRE CODE OFFICIAL. ORDER A KNOXBOX FROM KNOXBOX.COM. PLACEMENT TO BE MADE BY THE FDC."**
 - b) **Added Knoxbox location to plan at entry ways.**
- 3. **Sheet A2.5:**
 - a) Revised wall to 6" metal studs at drinking fountain in Lobby.
- 4. **Sheet A4.0:**
 - a) Added missing Keynote #4 for hot water tank exhaust.
 - b) Added missing exhaust keynote to plan.
- 5. **Sheet A6.0**
 - a) **Added key note 23 on sheet and Elevation 1. "Key Note 23. ADDRESS ABOVE DOOR MOUNTED ON CENTER PANE OF GLASS. ADDRESS TO BE 10"-12" VINYL CUT NUMBERS. COLOR: BLACK W/ WHITE OUTLINES AND A MINIMUM STROKE OF .5". "**
- 6. **Sheet A8.1:**
 - a) Removed filler cabinets from Detail #20 – Breakroom Elevation.
- 7. **Sheet A8.5:**
 - a) Coordinated Detail #1 – Breakroom Cabinetry Elevation with interior elevation and floor plan.
- 8. **Sheet A10.1:**
 - a) **Janitor’s Closet 109B Wall finishes have been modified to show FRP and paint.**

9. Sheet M1.0:

- a) Added references on plan to indicate that the exhaust outlets are sufficient distance from fresh air intakes.

10. Sheet P1.0:

- a) Added Pipe Materials Schedule to sheet.

11. Sheet P2.0:

- a) Added reference that the Pipe Materials Schedule is located on P1.0.

12. Sheet FP2.0:

- a) Added the fire plan review comments to sheet. Noted to refer to Architectural sheets for response to fire plan review comments 2 & 3.

13. Sheet E1.0:

- a) Added Keynote #17 for installation of back boxes to Plan Keyed notes and Lighting Plan.

14. Sheet E2.0:

- a) Revised locations of switching devices in Townhouse Room and Stacked Kennel Room for clarity.
- b) Added Keynote #24 to switching devices in Flex, Play, and Train Room, Large Daycare Group Boarding Room, Small Daycare and Group Boarding Room, Dog Boarding B, and Laundry Room.

END OF ADDENDUM 1