

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20191872
Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection		Failed	Wednesday, February 17, 2021

Corrective Action Required:

1	Misc	JOHN DIMAURO 1/21/2021
---	------	------------------------

IT APPEARS THAT DURING THE EXCAVATION FOR THE ELECTRICAL CONDUITS, SECTIONS OF THE SIDEWALK AND ADA RAMPS WERE UNDERMINED AND ARE NO LONGER INSTALLED ON A SUITABLE SUB GRADE. THESE SECTIONS OF SIDEWALK WILL NEED TO BE REPLACED. PHOTOS ARE UPLOADED.

Comments: