# **S** LEE'S SUMMIT MISSOURI

### **DEVELOPMENT SERVICES**

## **Residential Plan Review**

February 17, 2021

JFE CONSTRUCTION INC 1314 SW MARKET ST LEES SUMMIT, MO 64081 (816) 470-0074

| Permit No:       | PRRES20210619                                |
|------------------|--|
| Plan Name:       | 3010 NW THOREAU PL                           |
| Project Address: | 3010 NW THOREAU PL, LEES SUMMIT, MO 64081    |
| Parcel Number:   | 225568                                       |
| Location:        |  |
| Type of Work:    | NEW SINGLE FAMILY                            |
| Occupancy Group: | RESIDENTIAL, ONE- AND TWO-FAMILY             |
| Description:     | NEW HOUSE - FINISHED BASEMENT - COVERED DECK |
|                  | DEFERRED FLOOR JOISTS                        |

#### **Revisions Required**

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

| Plot Plan Review                     | Reviewed By: Kim Brennan                           | Rejected |  |  |  |
|--------------------------------------|--|----------|--|--|--|
| 1. Sidewalks with dimensions must be | with dimensions must be provided on the plot plan. |          |  |  |  |
| Residential Plan Review              | Reviewed By: Kim Brennan                           | Rejected |  |  |  |

1. Identify emergency escape openings from bedrooms and basement(s). (IRC Section R310 as amended per Ordinance)

2. Designate locations of smoke detectors and carbon monoxide detectors. (IRC Section R314 and R315)

3. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

4. Drawings must be sealed and stamped by a licensed professional in the State of Missouri

5. Detail required separation between garage and living area including door, door closer and gypsum board. (IRC R302.5)

Does not specify 20 minute rated

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

6. Provide size, spacing, species, and grade of rafter, ceiling joist materials and ridge and valley members. (IRC Section R802)

7. Identify location(s) of vertical supports and purlins. (IRC Section R802.5.1)

8. Specification of rafter ties or ridge beam design. (IRC Section 802.3.1)

9. Identify type of protection used in unfinished areas under floor trusses. (IRC Section R501.3)

10. Identify braced wall locations and length of braced wall panel(s). (IRC Section R602.10)

11. Specify type of wall bracing method(s) utilized. (IRC Section R602.10)

12. Specify acceptable material and size of exterior sheathing. (IRC Section R703)

# The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area:                  |    |                            |      |  |
|------------------------------------|----|----------------------------|------|--|
| Residential, Living Area           |    | 1952<br>361<br>1397<br>235 |      |  |
| Residential, Un-Finished basements |    |                            |      |  |
| Residential, Finished basements    |    |                            |      |  |
| Residential, Decks                 |    |                            |      |  |
| Residential, garage                |    | 665                        |      |  |
|                                    |    |                            |      |  |
| Roofing Material                   |    | Number of Bathrooms        | 4    |  |
| Number of Bedrooms                 | 5  | Number of Stories          | 1    |  |
| Number of Living Units             | 1  | Total Living Area          | 3349 |  |
| Sewer Connection Fee               | 17 |                            |      |  |