

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202961  
Address: 2366 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Residential</b>	John Morris	Failed	Thursday, February 18, 2021

Corrective Action Required:

1	Misc	Pressure test gas piping minimum 10psi for 15 minutes
---	------	---

**Comments:**