CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192766

Address: 1104 NE GOSHEN CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Piers/Caissons Inspection - Mark Harding Passed Thursday, February 18,

Residential 2021

Informational:

1 Misc CONVERSTION WITH CYRUYS COX -

cc CONCRETE TOOK OVER FORM THE PERVIOUS CONTRACTOR AND REDRILLED

THE PIERS 36" AND POURED THEM.

THE HOUSE AT 1108 WAS INSPECTECT AND POURED THE DAY BEFORE.

FROM THE CONVERSTION WE HAD THE PIERS ARE APPROVED. MARK HARDING

02/18/2021 4:30 PM

Comments: