

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204750
Address: 2005 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-----------------|----------|------------------------------|
| Underslab Plumbing Inspection - Residential | Michael Harkins | Failed | Friday, February 19, 2021 |

Corrective Action Required:

1 Misc Connect interior underslab drain tile to sump pit

Corrective Action Required:

2 Misc - BASEMENT COVERED WITH TARP EXPOSE DRIAN TILE FOR INSPECTION -

Comments: