

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204442
Address: 2009 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Michael Harkins	Failed	Friday, February 19, 2021

Corrective Action Required:

1	Misc	Complete interior underslab drain tile installation
---	------	---

Corrective Action Required:

2	Misc	- BASEMENT COVERED WITH TARP EXPOSE DRAIN TILE FOR INSPECTION -
---	------	---

Comments: