

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204589

Address: 196 NW OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Friday, February 19, 2021

Corrective Action Required:

1	Misc	- SECURE & PROVIDE COVER PLATE RECEPTACLE BEHIND DOOR TO RESTROOMS - - REPLACE BUG LIGHT SOUTH WALL - - PROVIDE ADDRESS BACK DOOR - - ADD UNIT "B" TO ADDRESS FRONT DOOR -
---	------	---

Comments: