

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204589

Address: 196 NW OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

<b>Occupancy Inspection - Codes Commercial</b>	Michael Harkins	Pending	
--	-----------------	---------	--

Corrective Action Required:

1	Misc	- SECURE & PROVIDE COVER PLATE RECEPTACLE BEHIND DOOR TO RESTROOMS - - REPLACE BUG LIGHT SOUTH WALL - - PROVIDE ADDRESS BACK DOOR - - ADD UNIT "B" TO ADDRESS FRONT DOOR -
---	------	---

Comments: