

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203598
Address: 2349 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Not Ready	Monday, February 22, 2021

Corrective Action Required:

1	Misc	-Fireblock all through floor Penetrations with code approved material -Fireblock top plate penetrations. bedroom 4 -Deck not ready for rough inspection
---	------	---

OK TO INSULATE
DO NOT ROCK

Comments: