

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202961
Address: 2366 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Not Ready	Monday, February 22, 2021

Corrective Action Required:

1	Misc	-deck not ready for rough inspection -Fireblock all through floor Penetrations -Penetrations in floor joists shall not be closer than 2 inches to the top or bottom of the member, or to any other hole located in the member. Replace or provide engineered solution for repair
---	------	--

Comments: