

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201772
Address: 3202 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Not Ready	Monday, February 22, 2021

Corrective Action Required:

1	Misc	-Fireblock bed 4 bath concealed space by tub at HVAC line set -fireblock through floor penetration, master bath -Provide engineered solution for repair of multiple top flange penetrations of engineered Joists, first floor framing -Provide water heater circuit
---	------	--

Comments: