



Wheeler Lumber

February 22, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

Re: Lot 77 The Reserve at Stoney Creek
1414 SW Georgetown Dr.
Lee's Summit, MO 64082
Permit #: PRRES20202150

To Whom it may concern:

I am writing this letter regarding the roof truss identified during inspection at the above address. The truss in question is a non-structural truss used as a plywood nailer only. As it is non-structural, no repair is required.

Sincerely,

Chance Lickteig
Designer/Estimator
Wheeler Lumber, LLC