

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20193544
Address: 2001 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Michael Harkins	Failed	Tuesday, February 23, 2021

Corrective Action Required:

1	Misc	Engineering Basin failed Planning complete landscaping Fire interior exit light east vestibule Fire Exterior light north entry Water backflow pending Complete base at FRP Complete signage Restroom mirrors, soap dispensers, paper towel holders Home training room 3 GFCI at sink & cover plates GFCI's exam room #3 not working Secure GFCI right of sink staff lounge Door Thresholds south loading zone Receptacle cover plate nurse manager room Receptacle cover plates under countertops treatment area Remove trash from roof
---	------	---

Comments:

