



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20210484	Date:	February 23, 2021
Project Title:	JORDAN'S CHIROPRACTIC	Applicant:	
Location:			
3552 SW MARKET ST, LEES SUMMIT, MO 64082		BAMFORD FIRE SPRINKLER CO INC	
Type of Work:		5134 MERRIAM DR	
Occupancy Group:	B	SHAWNEE MISSION, KS 66203	
Description:	TENANT FINISH FOR		
CHIROPRACTIC		Primary: (913) 432-6688	
Construction Type:	Type VB (Unprotected)		
Map Page:	amanda@amandaleeinteriors.com		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. (Informational Purposes)
Current annual inspection tag needed on the riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.