

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210484
Address: 3552 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------|--------------------|----------|----------------------------|
| In-wall Inspection | Patrick Schonfeldt | Failed | Tuesday, February 23, 2021 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -City stamped approved plans required on site for inspection - corrections list may be incomplete -Redundant ground MC per NEC 2017 517.13 (A) (B) -Protection plate at all DWV within 1 1/4" of end of stud - see restroom |
|---|------|---|

Comments: