

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202389  
Address: 4408 SW LODESTONE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Tuesday, February 23, 2021

Corrective Action Required:

1	Misc	-Deck ledger to cantilever attachment per plans - Ensure that attachment on site matches the referenced plan detail - specified galvanized lag bolts, rim joists with inverted hangers attached to cantilevered joists, blocking between joists at cantilever, etc.  -OK TO ROCK-
---	------	---

**Comments:**