

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20203599  
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Mandrel</b>	John DiMauro	Passed	Tuesday, February 23, 2021

Informational:  
1 Misc JOHN DIMAURO 02/23/2021

I observed the Redford crew pull the mandrel through SS line B with no deflection. I verified the correct mandrel was used for the 8" line.

Test Passed.

**Comments:**