

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20203599
Address: 2601 SW PRYOR RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Air Test	John DiMauro	Passed	Tuesday, February 23, 2021

Informational:
1 Misc JOHN DIMAURO 02/23/2021

I observed the SS psi test for both line segments on line B. Both sections of line held at 4 psi for the required time length with no drop.

Tests Passed.

Comments: