

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20200316
Address: 1704 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Not Ready	Wednesday, February 24, 2021

Corrective Action Required:

1 Misc

- Minimum 6 inch clearance from wood siding to grade below
- Grade must fall minimum 6 inches in the first 10 feet from foundation
- All exterior receptacles required to be GFCI protected, patio

Comments: