

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203170
Address: 1032 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Wednesday, February 24, 2021

Corrective Action Required:

1	Misc	-repair damaged vapor barrier, exterior -provide bottom at floor cantilevers, exterior -install windows -Continue soffit vent installation -complete HVAC line set
---	------	--

OK TO INSULATE AND ROCK

Comments: