

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204747
Address: 4406 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------------|----------|---------------------------------|
| Underslab Plumbing Inspection - Residential | Patrick Schonfeldt | Failed | Wednesday, February 24, 2021 |

Corrective Action Required:

| | | |
|---|-----------------------------|---|
| 1 | Miscellaneous Correction | -UNABLE TO INSPECT ALL DWV DUE TO MUD WATER COVER, PUMP OUT WATER OR WAIT FOR CONDITIONS TO ALLOW -INTERIOR DRAIN TILE RUN DIAGONAL MUST REACH OPPOSITE FOUNDATION FOOTING |
|---|-----------------------------|---|

Comments: