CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20200316

Address: 1704 SW 27TH ST, LEES SUMMIT, MO 64082

Inspected On: Thursday, February 25, 2021

Inspected By: John Morris

Expiration Date: 3/25/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - John Morris Temporary C of O Thursday, February

Codes Residential 25, 2021

Corrective Action Required:

1 Misc -Minimum 6 inch clearance from wood siding to grade below

-Grade must fall minimum 6 inches in the first 10 feet from

foundation

TCO VALID THROUGH 03/25/2021