

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20201254  
Address: 114 SE DOUGLAS ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer - Vacuum</b>	Joe Starlin	Passed	Wednesday, February 24, 2021

Informational:

1	Misc	7-13-20 11:10 They are testing manhole A-2 it is 17' deep so we will hold vacuum for 3 minutes. Manhole A-2 has not passed at this time. Manhole A-1 has passed. We are now testing A-3. A-3 has passed. They will be making corrections on A-2 manhole and we will retest.
---	------	--

**Comments:**