

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210484
Address: 3552 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Patrick Schonfeldt	Failed	Friday, February 26, 2021

Corrective Action Required:

1	Misc	-City stamped approved plans required on site for inspection - corrections list may be incomplete -Redundant ground MC per 2017 NEC 517.13 (A) (B) - see front treatment room east wall receptacle -Protection plat at all DWV within 1 1/4' of end of stud - see restroom
---	------	--

Comments: