



Feb 25, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue of cut truss for Lot # 77 Reserve at Stoney Creek – 1414 SW Georgetown Dr. Lee's Summit, MO 64082 – Permit # PRRES20202150

This letter addresses the non-structural lay in gable truss that was cut for roof vent above dining room.

Residential Engineering Services recommends:

- Install a 24" long scab of Douglas Fir Larch #2 2x4 centered over cut area.
- Install 2-1/2" long screws at 3" oc at both edges of scab.
- Truss is structurally sound after repair.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

