

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210484
Address: 3552 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Patrick Schonfeldt	Failed	Monday, March 01, 2021

Corrective Action Required:

1	Misc	--Redundant ground MC per 2017 NEC 517.13 (A) (B) - see front treatment room existing receptacles, existing wall. Allowed to carry over from in wall. Above ceiling inspection TBD
---	------	--

Comments: