## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20202309

Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

**Underslab Plumbing Inspection** John Morris Failed Tuesday, March 02,

- Residential 2021

Corrective Action Required:

1 Misc Provide positive or neutral slope of interior underslab drain tile throughout

**Comments:**