

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202150
Address: 1414 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, March 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Maintain gravel filter, clean mud and gravel from street -Roof vents covered by truss framing at foyer and garage
---	--------------------------	---

**** OK TO INSULATE, OK TO ROCK WALLS ONLY NOT CEILING LINE UNTIL ALL ROUGH PASSED****

Comments: